



PPG LABORATORY TEST RESULTS CERTIFICATION

ADHESION

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

COATING: DURANAR PLUS

TEST: ASTM D-3359 - Standard Test Methods for Measuring Adhesion by Tape Test

SPECIFICATION: Test Method B - A lattice pattern with eleven cuts in each direction (90 degree to each other) is made in the film to the substrate. A reverse impact is applied 1.5 x metal thickness in mils to the cross-hatched area. Pressure-sensitive #610 3M Scotch tape is applied over the reverse impacted lattice area and then removed rapidly.

RESULTS: There shall be no flaking and no loss of adhesion of the topcoat and primer from the pretreated substrate, 5B classification.

May 1, 2002