



PPG LABORATORY TEST RESULTS CERTIFICATION

ACCELERATED WEATHERING: W-O-M

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

COATING: DURANAR

TEST: ASTM D4587 and ASTM G53/G154 - Operating Light - and Water Exposure Apparatus (Fluorescent UV) for Testing Paint and Related Coatings and Materials.
ASTM D4214-Degree of Chalking of Exterior Paint Films, Method A-D659
ASTM D2244 -Calculation of Color Difference

SPECIFICATION: Coating should withstand a weathering test of 5000 hours in a Fluorescent UV/Condensation Weather-O-Meter, type D, run in accordance with the above test without cracking, peeling, blistering or loss of adhesion

RESULTS: No cracking, peeling, blistering or loss of coating adhesion. Color change is less than 5 delta E color units. Chalk will be no worse than an 8 rating.

Rev. 1/03