



PPG LABORATORY TEST RESULTS CERTIFICATION

ACID RESISTANCE NITRIC ACID VAPOR

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

COATING: DURANAR PLUS

TEST: AAMA 605.2, test #7.7.3

SPECIFICATION: A coated panel is placed over an eight ounce wide mouth bottle containing 50% full of 70% nitric acid solution at $77 \pm 5^\circ\text{F}$ for 30 minutes. The panel is withdrawn, washed with distilled water and allowed to recover for 1 hour before being examined for any effects of significant color change, blisters, and overall appearance.

RESULTS: No color change greater than 5 E units (Hunter), calculated in accordance with ASTM D2244, when comparing measurements on the acid-exposed area to the unexposed area.

May 1, 2002